



# Brandon Fire & Emergency Services

120-19th Street North  
Brandon, MB  
R7B 3X6

Phone: 204-729-2400  
Fax: 204-729-8970  
Email: fire@brandon.ca

## Inspection and Testing - Fire Alarm System

I, qualified personnel of \_\_\_\_\_ have inspected and tested the Fire Alarm System located at:

Was the entire fire alarm system inspected and tested in accordance with CAN/ULC-S536 "Standard for the Inspection and Testing of Fire Alarm Systems", as referenced by the current National Fire Code?                      YES                      NO

What method of smoke detector sensitivity equipment was used? \_\_\_\_\_

Does the system provide a:    single-stage operation \_\_\_\_\_ two-stage operation \_\_\_\_\_

If the fire alarm system is monitored by a fire signal receiving centre, did the fire signal receiving centre verify that they received the correct signals?

Alarm \_\_\_\_\_ Trouble \_\_\_\_\_ Supervisory \_\_\_\_\_

Upon completion of the inspection, did the fire alarm system operate properly?

YES                      NO

If no, were they corrected?

YES                      NO

Is the fire alarm system fully functional?

YES                      NO

**Any NO answer requires a deficiency report to be completed and retained in your inspection binder to be available upon request.**

REMINDER: As per The National Fire Code, maintenance inspections are required annually.

*Please have this form completed by the person who performed the inspection.  
BFES requires that a copy to be available upon request as well as for your own records.*

Signature: \_\_\_\_\_

Date: \_\_\_\_\_

Inspector:

File Number: